



State Water Resources Control Board

Division of Drinking Water

August 14, 2014

Rachel Arias Mountains Sector Maintenance Chief II California State Parks – Big Basin 21600 Big Basin Way Boulder Creek, CA 95006

Attention Ms. Arias:

CITATION NO. 02-05-14C-011-4410301-02 CITATION FOR TOTAL TRIHALOMETHANE MCL EXCEEDANCE CALIFORNIA STATE PARKS - BIG BASIN (SYSTEM NO. 4410301)

Enclosed is a Citation issued to the California State Parks – Big Basin (CSP Big Basin) water system for failure to comply with primary maximum contaminant level (MCL) for Total Trihalomethanes (TTHM) as specified in Section 64533(a) of the California Code of Regulations.

CSP Big Basin failed to comply with the locational total trihalomethane (TTHM) MCL at the Little Basin Main Office sample site. Following quarterly chemical TTHM analysis completed on May 21, 2014, the Little Basin Main Office site exceeded the TTHM MCL of 0.080 mg/L (80 ug/L) with a running annual average TTHM concentration of 0.103 mg/L (103 ug/L).

CSP Big Basin distributed a Tier 2 public notification to its residents on July 23, 2014, and submitted proof of notification to the Division on July 23, 2014. Please send proof of third quarter 2014 (July 1st – September 30th) public notification to the Division by **October 10, 2014**.

The Citation consists of five sections: Applicable Authorities, Statement of Facts, Determination, Directives, and Further Enforcement Actions. The Applicable Authorities and Statement of Facts sections describe the events leading to the issuance of the Citation. The Directives section specifies required actions that must be implemented by the water system to return to compliance. The Further Enforcement Actions section describes penalties to be assessed for failure to comply with the Citation. No civil penalty is levied with the attached Citation.

Your water system will be billed at the Division's hourly rate for the time spent on issuing this Citation since this is an enforcement action for noncompliance with state regulations. The water system will receive a bill from our Fee Billing Unit in Sacramento.

If you have any questions regarding this matter, please contact Jonathan Weininger at (831) 655-6932 or me at (831) 655-6934.

Sincerely,

Jan R. Sweigert, P.E.

District Engineer, Monterey District Office Northern California Field Operations Branch Drinking Water Program

CERTIFIED MAIL NO.: 7008-1830-0004-5435-0608

Enclosures:

Citation No. 02-05-14C-011-4410301-02 Attachment A: Proof of Notification Form

cc: Santa Cruz Environmental Health Department (w/out attachments)

1 STATE OF CALIFORNIA 2 WATER RESOURCES CONTROL BOARD **DIVISION OF DRINKING WATER** 3 4 TO: 5 California State Parks – Big Basin 6 CSP Big Basin 7 303 Big Trees Park Road 8 Felton, CA 95018 9 10 Attn: Ms. Rachel Arias, Maintenance Supervisor 11 California State Parks – Big Basin 12 CITATION FOR VIOLATION OF CALIFORNIA CODE OF REGULATIONS, 13 14 TITLE 22, SECTION 64533(a) - WATER SYSTEM NO. 4410301 15 CITATION NO. 02-05-14C-011-4410301-02 16 Issued on August 14, 2014 17 18 Section 116650 of the California Health and Safety Code authorizes the issuance of 19 a citation to a public water system for violation the California Safe Drinking Water Act 20 (Health and Safety Code, Division 104, Part 12, Chapter 4, commencing with Section 21 116270) (hereinafter "California SDWA"), or any regulation, standard, permit or order 22 issued or adopted thereunder. 23 24 The State Water Resources Control Board, acting by and through its Division of 25 Drinking Water (hereinafter "Division") and the Deputy Director for the Division 26 (hereinafter "Deputy Director"), hereby issues a citation to the California State Parks 27 Big Basin Water System (hereinafter, CSP Big Basin) (303 Big Trees Park Rd. Felton,

1	CA 95018) for violation of California Code of Regulations (CCR), Title 22, Section	
2	64533 subsection (a).	
3	APPLICABLE AUTHORITIES	
4	Section 116650 of California Health and Safety Code provides:	
5	(a) If the department determines that a public water system is in violation	
6	of this chapter or any regulation, permit, standard, citation, or order issued or adopted	
7	thereunder, the department may issue a citation to the public water system. The	
8	citation shall be served upon the public water system personally or by certified mail.	
9	Service shall be deemed effective as of the date of personal service or the date of	
10	receipt of the certified mail. If a person to whom a citation is directed refuses to accept	
11	delivery of the certified mail, the date of service shall be deemed to be the date of	
12	mailing.	
13	(b) Each citation shall be in writing and shall describe the nature of the	
14	violation or violations, including a reference to the statutory provision, standard, order,	
15	citation, permit, or regulation alleged to have been violated.	
16	(c) A citation may specify a date for elimination or correction of the	
17	condition constituting the violation.	
18	(d) A citation may include the assessment of a penalty as specified in	
19	subdivision (e).	
20	(e) The department may assess a penalty in an amount not to exceed	
21	one thousand dollars (\$1,000) per day for each day that a violation occurred, and for	
22	each day that a violation continues to occur. A separate penalty may be assessed for	
23	each violation.	
24		



25

26

1	California Code of Regulations, Title 22, Section 64533, subsection (a) provides,			
2	in relevant part:			
3				
4	(a) Using the monitoring and calculation methods specified in sections			
5	64534, 64534.2, 64535, and 64535.2, the primary MCLs for the disinfection			
6	byproducts shown in table 64533-A shall not be exceeded in drinking water supplied			
7	to the public.			
8				
9	Table 64533-A			
10	Maximum Contaminant Levels and Detection Limits for			
11	Purposes of Reporting Disinfection Byproducts			
12	Maximum Detection Limit for			
13	Contaminant Purposes of Reporting			
14	Disinfection Byproduct Level (mg/L) (mg/L)			
15	Total trihalomethanes (TTHM) 0.080			
16	Bromodichloromethane 0.0010			
17	Bromoform 0.0010			
18	Chloroform 0.0010			
19	Dibromochloromethane 0.0010			
20				
21	STATEMENT OF FACTS			
22	The CSP Big Basin water system is operated under Water Supply Permit No. 86-009,			
23	issued on March 13, 1986.			
24				
25	CSP Big Basin serves water to an estimated transient population of 3,000. CSP Big			
26	Basin is located in the Santa Cruz Mountains. CSP Big Basin consists of one local			
27	surface water source (Sempervirens Reservoir), one microfiltration and GAC surface			



1	water treatment plant, sodium hypochlorite for disinfection, and seven storage tanks	
2	(six redwood and one stainless steel).	
3	Pursuant to Title 22, CCR, Section 64534.2(d), CSP Big Basin is required to collect	
4	two distribution system samples per quarter for TTHM and HAA5 analyses in	
5	accordance with their approved Stage 2 DBPR Monitoring Plan. Under Title 22, CCR,	
6	Section 64535.2(b)(1), compliance with the TTHM MCL of 0.080 mg/L is based on	
7	running annual average, calculated quarterly, for each monitoring location.	
8		
9	The following is a chronology of events that occurred leading up to the TTHM MCL	
10	failure at the Little Basin Main Office Monitoring Location:	
11		
12	4 th Quarter 2013 (November 21, 2013): Little Basin Main Office TTHM Result: 84	
13	ug/L.	
14		
15	1st quarter 2014 (February 19, 2014): Little Basin Main Office TTHM Result: 170 ug/L.	
16	Running annual average value (4Q2013+1Q2014) / 4 = 63.5 ug/L.	
17		
18	2 nd Quarter 2014 (May 21, 2014): Little Basin Main Office TTHM Result: 160 ug/L.	
19	Running annual average value (4Q2013+1Q2014+2Q2014) / 4 = 103.5 ug/L.	
20		
21	Following the second quarter 2014, with three quarters of TTHM results, CSP Big	
22	Basin's TTHM running annual average is calculated to be 103.5 ug/L, which exceeds	
23	the TTHM MCL of 80 ug/L.	
24	9	
25		



1 DETERMINATION 2 The Division has determined that CSP Big Basin failed to comply with the Maximum 3 Contaminant Level (MCL) for total trihalomethanes (TTHM) at the Little Basin Main 4 Office site for the three-quarter monitoring period of October 1, 2013, through June 5 30, 2014. For a public water system monitoring quarterly, each locational running 6 annual average (LRAA), computed quarterly, shall not exceed the MCL of 0.080 mg/L 7 (80 μg/L) for total trihalomethanes, consisting of chloroform, bromodichloromethane. dibromochloromethane, and bromoform. The TTHM LRAA for the three-quarter 8 9 monitoring period of October 1, 2013, through June 30, 2014, was 103.5 µg/L at the 10 Little Basin Main Office sample site. 11 12 CSP Big Basin distributed a Tier 2 public notification to its residents and posted the 13 notice in public places on July 24, 2014. CSP Big Basin provided proof of notification to the Division on July 24, 2014. 14 15 16 **DIRECTIVES** 17 18 CSP Big Basin is hereby directed to take the following actions: 19 20 1. Forthwith, CSP Big Basin shall cease and desist from failing to comply with the 21 MCL for total trihalomethanes (TTHM). 22 23 2. Effective Immediately, CSP Big Basin shall post Division-approved notices at 24 residences and in public locations. These notices must be updated quarterly until 25 such time that the Division notifies CSP Big Basin that monitoring results indicate

that CSP Big Basin has returned to compliance with the TTHM MCL. Proof of

Page 5 of 8



26

1	notification shall be sent to the Division within 10 days following the end of eac		
2		quarter that CSP Big Basin is still in violation of the TTHM MCL.	
3			
4	3.	By November 30, 2014, , CSP Big Basin shall submit to the Division for review	
5		and approval, a plan and compliance schedule for improvements to the water	
6		system to correct the TTHM water quality problem and eliminate the delivery of	
7		water to consumers that does not meet the TTHM primary drinking water	
8		standards. Following submittal of the schedule, the System shall submit monthly	
9		progress reports to the Division by the tenth day of each month until the System	
10	returns to compliance.		
11			
12	4.	4. By December 31, 2015, CSP Big Basin shall complete all the improvements in the	
13	proposed project submitted pursuant to Directive 3 above in accordance with the		
14	compliance schedule to be reviewed and approved by the Division.		
15		e e	
16	5.	By September 10, 2014, CSP Big Basin shall submit a written response to the	
17		Division indicating its willingness to comply with the Directives of this Citation.	
18			
19	6.	CSP Big Basin shall include information regarding the TTHM MCL violation	
20		identified in this Citation in the 2014 Consumer Confidence Report, which must be	
21		completed and distributed by July 1, 2015. A draft of the 2014 Consumer	
22		Confidence Report shall be submitted to the Division for review and approval prior	

23

24

to distribution and/or posting.

1	The Division reserves the right to make such modifications to this Citation as it may
2	deem necessary to protect public health and safety. Such modifications may be
3	issued as amendments to this Citation, and shall be deemed effective upon issuance.
4	
5	Nothing in this Citation relieves CSP Big Basin of its obligation to meet the
6	requirements of the California Safe Drinking Water Act, or of any regulation, permit,
7	standard, or order issued or adopted thereunder.
8	
9	All submittals required by this Citation shall be submitted to the Division at the
0	following address:
11 12 13 14 15 16 17	Jan Sweigert, P.E. District Engineer State Water Resources Control Board Division of Drinking Water 1 Lower Ragsdale Dr., Bldg. 1, Suite 120 Monterey, CA 93940
9	PARTIES BOUND
20	This Citation shall apply to and be binding upon CSP Big Basin, its officers, directors,
21	shareholders, agents, employees, contractors, successors, and assignees.
22	
23	SEVERABILITY
24	The Directives of this Citation are severable, and CSP Big Basin shall comply with
25	each and every provision thereof, notwithstanding the effectiveness of any other
26	provision.
27	
28	



FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Division to: issue citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation, permit or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Division to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with an order of the Division; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with violates an order of the Division. The Division does not waive any further enforcement action by issuance of this citation.

13

1

2

3

4

5

6

7

8

9

10

11

12

14 15

16

17

18 19

20 21 22

23

Attachments:

24 25

26 2.7

28

CC:

Jan Sweigert, P.E.

District Engineer

Division of Drinking Water

State Water Resources Control Board

1. Proof of Notification Form

County of Santa Cruz, Department of Environmental Health



Page 8 of 8

PROOF OF NOTIFICATION

Name of Water System: California State Parks - Big Basin

System Number: 4410301

Certification

As required by Section 64463.4 of the California Code of Regulations, I notified the users of the water supplied by California State Parks – Big Basin of the TTHM violation of Section 64533(a) of the California Code of Regulations for the compliance period of July 1, 2014 to September 30, 2014. I complied with the directives of this order as indicated below:

Required Action	Date Completed
Public Notification – Mail or Direct Delivery	
Public Notification – Posting in Public Places Served by the Water System or publication in a newspaper	*
by the trater eyetem of publication in a newspaper	
Signature of Water System Representative	Date

Attach a copy of the direct delivery/mail notice and a copy of the public posting.

THIS FORM MUST BE COMPLETED AND RETURNED TO THE DIVISION